



Guelph Fire Department

Mobile Food Vehicle Self-Inspection Checklist

Online version of this survey is available at http://guelph.ca/BLFIRE		Yes	No	N/A
GENERAL				
Bylaw 2009-18855				
1	All documents have the name of the business, name of the owner of the vehicle and the name of the operator of the vehicle and are in your possession.			
2	Contact phone numbers and emails if you need to be contacted for any matter relating to fire safety are readily available.			
3	A clear description of where the mobile food/beverage truck will be located (as provided to you by city staff) is available.			
Comments				
APPLIANCES				
Bylaw 2009-18855				
4	Must possess a current certificate from TSSA that an inspection has been carried out and that the appliances and vehicle are acceptable to be operated.			
5	The appliance serial number is in a visible location and legible for inspectors.			
6	The appliance manufacturer name is clearly visible and legible for inspectors.			
7	If the vehicle contains provisions for deep frying with cooking oils, it must contain a charged portable fire extinguisher with a class K rating or a class 20BC or higher rating			
8	In addition to the requirements for deep frying a vehicle must contain a portable extinguisher with a minimum class 2A10BC rating			
8.1	All extinguishers have been subjected to maintenance within the past 12 months by a qualified person			
9	The venting equipment for grills, fryers, burners or other open cooking appliances is installed to NFPA 96 – Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.			
10	Fixed extinguishing systems installed for grills, fryers, burners or other open cooking appliances are installed to NFPA 96 – Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.			
10.1	Inspection tag is affixed to the fire protection/exhaust systems showing the last inspection date and that the inspection was conducted within the last 6 months by a qualified person			
11	Cooking appliances have been cleaned and are free of grease build-up or food remnants			
12	Owner, operator or other workers on these mobile vehicles are knowledgeable in the use of portable fire extinguishers, manually activating the fixed extinguishing system if it fails to discharge and exhaust system operation			
Comments				



Guelph Fire Department

Mobile Food Vehicle Self-Inspection Checklist

Online version of this survey is available at <http://guelph.ca/BLFIRE>

I/we the individual/s completing this survey hereby acknowledge and declare that;
I/we have read, understood and are in compliance with all items listed in this checklist.
The information contained in this form is true and complete to the best of my/our knowledge, and that failure to provide complete or accurate information may delay the licensing process;

Name(print) _____ Signature _____

Business Name _____ Business Address _____

Business Phone _____ Business Licence Number (Renewal Only) _____

This self-inspection checklist is based upon Bylaw 2009-18855 and does not imply or limit the responsibility of the owner or owner's representative to carry out all of the provisions of Bylaw 2009-18855. A copy of this checklist shall be forwarded to
The Guelph Fire Department via one of the following:

By E-mail: fireprevention@guelph.ca

By Fax: 519-824-2147 or

by mail:

Fire Prevention
50 Wyndham St. S,
Guelph, ON, N1H 4E1

If you have any questions, please direct them to:

Guelph Fire Department
Fire Prevention Division 50
Wyndham St. S.
519-763-8111