



**FINISHED GRADE:**

- REFER TO PLANS FOR MATERIAL
- SET ELEVATION 13mm BELOW EDGE OF PATHWAY TO PREVENT PONDING

**LIMESTONE SCREENINGS:**

- 100mm DEPTH
- COMPACTED TO 95% S.P.D. MIN.

**GRANULAR 'A' OR 19mm Ø CRUSHER RUN LIMESTONE:**

- 150mm DEPTH
- COMPACTED TO 98% S.P.D. MIN.

**NON-WOVEN GEOTEXTILE:**

- TERRAFIX 270R OR APPROVED EQUAL
- IF REQUIRED, PER GEOTECHNICAL RECOMMENDATIONS

**SUB-GRADE:**

- EXISTING TOPSOIL TO BE REMOVED AND SUB-GRADE PROOF-ROLLED
- COMPACT SUB-GRADE
  - UNDISTURBED TO 95% S.P.D. MIN.
  - DISTURBED TO 98% S.P.D. MIN.

**NOTE:**

1. REFER TO PLANS FOR PROPOSED PATHWAY WIDTH AND GRADING.
2. ENSURE POSITIVE DRAINAGE ON PATHWAY SURFACE. WATER MUST NOT BE COLLECTED AND CONVEYED ALONG PATHWAY SURFACE.
3. REPAIR AND RESTORE ANY DAMAGE TO EXISTING CONDITIONS.
4. DETAIL TO BE READ IN CONJUNCTION WITH GEOTECHNICAL REPORT AND ADJUSTED PER RECOMMENDATIONS.
5. DETAIL TO BE READ IN CONJUNCTION WITH SPECIFICATIONS.
6. ALL MEASUREMENTS ARE IN MILLIMETERS UNLESS STATED OTHERWISE.