



**NOTE:**

1. REFER TO PLANS FOR PROPOSED ASPHALT WIDTH AND GRADING.
2. ENSURE A CLEAN, FLUSH TRANSITION BETWEEN PAVING, MAXIMUM VERTICAL CHANGE IN LEVEL IS 6mm.
3. PONDING ON ASPHALT PAVING WILL NOT BE ACCEPTED.
4. ENSURE POSITIVE DRAINAGE ON ASPHALT SURFACE. WATER MUST NOT BE COLLECTED AND CONVEYED ALONG ASPHALT SURFACE.
5. DO NOT BACKFILL AGAINST ASPHALT MINIMUM 48 HOURS UNTIL ASPHALT HAS CURED.
6. REPAIR AND RESTORE ANY DAMAGE TO EXISTING CONDITIONS.
7. DETAIL TO BE READ IN CONJUNCTION WITH GEOTECHNICAL REPORT AND ADJUSTED PER RECOMMENDATIONS.
8. DETAIL TO BE READ IN CONJUNCTION WITH SPECIFICATIONS.
9. ALL MEASUREMENTS ARE IN MILLIMETERS UNLESS STATED OTHERWISE.