



NOTES:

1. ACCESSIBLE RAMP LAY OUT SHALL ALLOW FOR ALTERNATE CURB OR EDGE DESIGN.
2. SOME SITUATIONS MAY REQUIRE AN ALTERNATIVE DESIGN, TO BE APPROVED BY THE CITY.
3. CONCRETE FORMS AND LAYOUT TO BE APPROVED BY CONTRACT ADMINISTRATOR PRIOR TO POURING CONCRETE.
4. ALL CONCRETE TO HAVE A COMPRESSIVE STRENGTH OF 32MPa @ 28 DAYS.
5. ALL EXPOSED FACES OF CONCRETE TO BE BROOM FINISH, RUNNING PERPENDICULAR TO DIRECTION OF SLOPE.
6. ENSURE A CLEAN, FLUSH TRANSITION BETWEEN CONCRETE RAMP AND ADJACENT MATERIALS. MAXIMUM VERTICAL CHANGE IN LEVEL IS 6mm.
7. REPAIR AND RESTORE ANY DAMAGE TO EXISTING CONDITIONS.
8. ALL MEASUREMENTS ARE IN MILLIMETERS UNLESS STATED OTHERWISE.