



NOTES:

- ACCESSIBLE RAMP LAYOUT SHALL ALLOW FOR ALTERNATE CURB OR EDGE DESIGN.
- SOME SITUATIONS MAY REQUIRE AN ALTERNATIVE DESIGN, TO BE APPROVED BY THE CITY. 2.
- CONCRETE FORMS AND LAYOUT TO BE APPROVED BY CONTRACT ADMINISTRATOR PRIOR TO POURING CONCRETE.
- ALL CONCRETE TO HAVE A COMPRESSIVE STRENGTH OF 32MPa @ 28 DAYS.
- ALL EXPOSED FACES OF CONCRETE TO BE BROOM FINISH, RUNNING PERPENDICULAR TO DIRECTION OF SLOPE.
- ENSURE A CLEAN, FLUSH TRANSITION BETWEEN CONCRETE RAMP AND ADJACENT MATERIALS. MAXIMUM VERTICAL CHANGE IN LEVEL IS 6mm.
- 7. NO EXPANSION JOINTS SHALL BE INSTALLED WITHIN SLOPED PORTIONS OF RAMP.
- REPAIR AND RESTORE ANY DAMAGE TO EXISTING CONDITIONS.
- ALL MEASUREMENTS ARE IN MILLIMETERS UNLESS STATED OTHERWISE.



PLAY AREA ACCESSIBLE RAMP **OUTSIDE OF CURB**

DECEMBER 2024

1:25