



NOTE: METER MUST BE INSTALLED ON HORIZONTAL PLAIN

NOTES TO BUILDER AND PLUMBER

1. ALL METERS MUST BE ACCESSIBLE FOR READING AND REPLACEMENT. ANY OBSTRUCTIONS WILL BE BASIS FOR TERMINATION OF THE WATER SUPPLY.
2. ALL WATER METERS ARE MARKED WITH A FLOW DIRECTIONAL ARROW. PLEASE ENSURE ARROW CORRESPONDS WITH WATER FLOW.
3. REMOVE METER FROM SERVICE BEFORE SOLDERING. HEAT AND SOLDER WILL DAMAGE THE INNER COMPONENTS OF THE WATER METER. AN INVOICE WILL BE FORWARDED FOR ANY DAMAGED METERS.
4. ALL METER SETS MUST HAVE A RISING STEM GATE VALVE BEFORE AND AFTER AS WELL AS A BY-PASS WITH A RISING STEM GATE VALVE AS THE DRAWING INDICATES.
5. ALL WATER METERS MUST BE INSTALLED USING THE SUPPLIED METER FLANGES AND GASKETS.
6. 2" CLEARANCE ABOVE AND 3" CLEARANCE IN FRONT OF THE WATER METER IS MANDATORY.
7. BY-PASS TO BE NO MORE THAN 4' OFF FLOOR.
8. BY-PASS TO BE COPPER.
9. THE CITY WILL SUPPLY ONE 3" COMPOUND WATER METER, ONE 3" STRAINER (TO BE INSTALLED BEFORE WATER METER AS SHOWN), METER FLANGES, GASKETS AND NUTS/BOLTS FOR METER SET.
10. WATER METER AND STRAINER TO BE INSTALLED BY THE BUILDER / PLUMBING CONTRACTOR TO THE REQUIREMENTS OF THE CITY OF GUELPH.
11. METER / STRAINER MEASUREMENTS MAY VARY.
10. WATER METER REMOTE WIRING TO BE INSTALLED BY THE BUILDER / PLUMBING CONTRACTOR. SEE WATER METER WIRE SPECIFICATIONS FOR MORE INFORMATION.
11. CALL WATER SERVICES 519-837-5627 FOR FURTHER ASSISTANCE.



3" COMPOUND METER SET - STANDARD

| | | | |
|---------|-----|-------|---------------|
| DRAWN | DJF | SCALE | N.T.S. |
| CHECKED | | DATE | February 2018 |